

RESPONSE TO QUERIES OF VENDORS IN PRE-BID MEETING HELD ON 15-06-2020
For Tender Notice No. IDRBT/AEP/VGB/776/2020-2021 dt. 25th May 2020

<u>SL.</u>	<u>DESCRIPTION OF QUERY</u>	<u>RESPONSE FROM IDRBT</u>
1.	<u>Product Technical Specifications on Page no. 13 of RFP, Sl. No. 1</u> Removal of "RACK MOUNT" from the description.	The descriptions stands modified to: "40 KVA on-line Modular UPS with 60 KVA rack and modules of 10 KVA."
2.	Suggestion to only have 10 KW modules instead of both options of 6.7 KW & 10 KW & to have option for 20 KW module along with 6.7 KW & 10 KW.	Since there are various configurations of modules available in the market, in order to maintain uniformity in the bids, it is decided to consider as under: "Bids for 10 KW modules shall only be considered. Accordingly, the Price Bid/Quote as stated in field 2 (b) on page 23 of RFP shall only be considered."
3.	<u>Product Technical Specifications on Page no. 13 of RFP, Sl. No. 12</u> Revision of description "Static Bypass Switch OR equivalent or better" as "Individual Static switch & Manual bypass Switch"	The Description stands modified to: "Individual Static switch & Manual bypass Switch."
4.	<u>Product Technical Specifications on Page no. 13 of RFP, Sl. No. 13</u> Replacing "in-built transformer" in the description with "External Isolation Transformer".	The Description stands modified to: "Microprocessor controlled, double conversion, and true on-line with external isolation transformer (price of external isolation transformer shall be included in the price of UPS system)".
5.	<u>Battery Specifications on Page no. 15 of RFP, Sl. No. 2</u> Addition of "Amara Raja" brand in the list of approved battery makes.	Brand "Amara Raja" is added in the list of approved makes of batteries.
6.	Addition of Hot-Swappable Feature in the product Specifications	Addition of product technical specifications on page no. 13 of RFP document at Sl. No. 20. "System must be "hot-swapping" enabled for replacement of modules without the requirement of a shutdown".
7.	Addition of Display specifications in "Display Specifications" on page no. 14 of RFP. "Each module should have provision for individual parameters display"	Addition of Sl. No. 11 of "Display" on page no. 14 of RFP document. The description reads as follows: "Each module must have provision for display of individual parameters or a consolidated display on the rack which can display parameters of each module individually."
8.	Suggestions to include additional certifications apart from those mentioned in RFP document on page no. 13 which reads "ISO 9001:2008 & 14001 certified and CE certification"	Prospective bidders are encouraged to furnish evidence of certifications in addition to those mentioned in the RFP.

In order to allow adequate time for prospective bidders to participate in this tender, the last date of submission stands revised to 7th July 2020 till 17:00 hours.

S/d
Deputy General Manager (Estate)